FINAL REPORT

CERTIFICATE No.: 26456



Boral Cement Limited ABN 62 008 528 523 Taylor Avenue New Berrima NSW 2577 Locked Bag 4 New Berrima NSW 2577 T +61 2 4860 2222

TEST CERTIFICATE OF:	Tarong Daily Despatch Grade 1 Fly Ash
PRODUCED AT:	Boral Cement Limited Tarong
TESTED AT:	Berrima Works Laboratory
SAMPLE IDENTIFICATION:	TDDFA2404487
DATE DESPATCHED:	9/25/2024

PROPERTY	REQUIRE	MENTS OF AS 3582.1 - Grade 1	RESULT
Fineness (AS 3583.1)	≥	75 %	82 %
LOI (AS 3583.3)	≤	4.0 %	1.3 %
Moisture (AS 3583.2)	≤	0.5 %	0.2 %
SiO ₂ (AS 2350.2)			72.0 %
Al ₂ O ₃ (AS 2350.2)			23.2 %
Fe ₂ O ₃ (AS 2350.2)			0.7 %
Chemical Composition (AS 2350.2)	2	70 %	96 %
Total Alkali (AS 2350.2)			0.5 %
CI (AS 2350.2)	≤	0.1 %	0.00 %

REMARKS

Sampling not carried out by laboratory. Samples tested as received and results only relate to the item tested.

Jason Nairn National Technical Manager



Page 1 of 1 Report Template - Rev. (3) Jul 2021 Authorised by M. A.

Boral Construction Materials Materials Technical Services

Unit 4, 3-5 Gibbon Road, Baulkham Hills NSW 2153 Australia PO Box 400, Winston Hills NSW 2153

> T +61 (02) 9624 9900 **boral.com.au**

TEST REPORT - FLYASH

CLIENT:	BORAL CEMEN	JT – (TECHNICAL)	FILE NO:	50/24
ADDRESS:	39 Delhi Road,	North Ryde, NSW 2113	REQUEST NO:	114904
SAMPLE IDI	ENTIFICATION:	TDDFA2404487	LAB SAMPLE NO:	310560
SOURCE OF	SAMPLE:	Queensland	DATE SAMPLED:	25/09/2024
			DATE RECEIVED:	27/09/2024

IDENTIFICATION OF CEMENT USED: Boral Cement SL Berrima Ref. 2022

TEST METHOD: AS 3583: Methods of test for supplementary cementitious materials for use with Portland cement

PROPERTY	DATE TESTED	RESULT	TEST METHOD	
Relative density	09/10/2024	2.07	AS 3583.5	
Relative water requirement	10/10/2024	103%	AS 3583.6	
Relative strength 7 days (accelerated)	17/10/2024	98%	AS 3583.6	

Note:

• Sample supplied by the client and tested as received.

Melody Mancenido, Parisa Sowti, Violeta Paicu, Jason Nairn, Mat. File, File

Sam El-Hamawi Approved signatory CEM114904.SE.1 21 2024 10 Date _ Serial no.



Accredited for compliance with ISO/IEC 17025 – Testing

This report shall not be reproduced in full without the approval of the Boral MTS Laboratory. Test results in this Test Report relate only to the samples tested. NATA Accredited Laboratory Number: 547